

Technical Compliance Statement



Ref. No.: ACWE-RC180065 (ACWE-C1W1802008)

For the following equipment

Applicant : Jiangsu Goodwe Power Supply Technology Co.,Ltd.
Manufacturer : Jiangsu Goodwe Power Supply Technology Co.,Ltd.
Product : Smart Meter
Model Number : (1)GM3000 (2)GM1000
Brand : GOODWE

We, **AUDIX Technology (Wujiang) Co., Ltd. EMC Dept.** hereby certify that the above product has been tested by us with the listed standards and found in compliance with the council EMC directive 2014/30/EU. The test data & results are issued on the EMC test report No. **ACWE-E1805003**.

Emission: **EN 61326-1:2013**

EN 61000-3-2: 2014 and EN 61000-3-3:2013

Immunity: **EN 61326-1:2013**

(IEC 61000-4-2:2008, IEC 61000-4-3:2006+A2:2010,

IEC 61000-4-4:2012, IEC 61000-4-5:2014,

IEC 61000-4-6:2013, IEC 61000-4-8:2009, IEC 61000-4-11:2004)

May 15, 2018

Ken Lu/ Assistant General Manager
AUDIX Technology (Wujiang) Co., Ltd. EMC Dept.



Deutsche
Akkreditierungsstelle
D-PL-18968-01-00

The statement is based on a single evaluation of one sample of the above-mentioned product. It does not imply an assessment of the whole production and does not permit the use of the test lab logo.